

NOTES:

1. DRYWELL SHALL EXTEND A MINIMUM OF 3' - 0" INTO GRAVEL STRATA. EXACT LOCATION OF GRAVEL STRATA SHALL BE DETERMINED IN THE FIELD BY THE PROJECT ENGINEER.
2. THE SMALLEST DRYWELL SHALL CONSIST OF TWO 3' - 0" SECTIONS.
3. ADDITIONAL 3' - 0" SECTIONS MAY BE REQUIRED DEPENDING UPON THE DEPTH OF THE GRAVEL STRATA.
4. THE CONTRACTOR SHALL, PRIOR TO ORDERING PIPE SECTIONS FOR DRYWELL, SUBMIT TO THE PROJECT ENGINEER DETAILS OF THE PROPOSED PIPE SECTION FOR HIS WRITTEN APPROVAL, THE PIPE SECTIONS SHALL BE MADE OF REINFORCED CONCRETE.

