

- ① OUTSIDE INSTALLATIONS MAY BE USED ONLY WITH PRIOR APPROVAL OF THE ENGINEER (ALL SIZES)
- ② 24" I.D. TILE FOR FORD NO. W3 LID AND NO. 2 EXTENSION RING OR EQUAL
- ③ CURB STOP TO BE FORD TYPE B22-444, HAYS 4304, OR EQUAL
- ④ TILE SHALL BE CONCRETE OR VITRIFIED CLAY OR PVC
- ⑤ FORD BOX TO BE LOCATED NO MORE THAN 3' - 0" FROM CURB BOX AT PROPERTY LINE OR AS DIRECTED BY THE ENGINEER.



FORD CATALOG YOKE NO.	SERVICE PIPE SIZE	METER	SPREAD	TILE SIZE
502	3/4"	5/8" x 3/4"	12 1/2"	24" DIA.
504	1"	1"	16 5/8"	24" DIA.